

Good Morning Support Community,

The Canadian government has issued a recall notice for specific fire extinguishers sold in Canada. This recall involves two styles of Kidde-branded and Garrison-branded fire extinguishers: Plastic Handle Fire Extinguishers and Push-Button Pindicator Fire Extinguishers. The fire extinguisher can become clogged or require excessive force to discharge and can fail to activate during a fire emergency. In addition, the nozzle may detach with enough force to pose an impact hazard.

The Agency is asking all Supportive Roommates to visit <http://healthycanadians.gc.ca/recall-alert-rappel-avis/hc-sc/2017/65014r-eng.php> to verify that their fire extinguishers have not been recalled. Consumers may contact Kidde toll-free at 855-233-2882 from 8:30 a.m. to 5 p.m. ET Monday through Friday (excluding holidays), or between 9 a.m. and 3 p.m. on weekends. You can also go to <https://inmarmarketaction.com/kidde/Kidde284CA/> for recall instructions.

Thank you,

The Agency